

		HOJA DE DATOS		DOCUMENTO Nº SC-E01-IC-HD-005	
		CLIENTE: YPFB TRANSPORTE S.A.		HOJA: 1 de 1	
		PROYECTO: MEJORAS MEDICION TERMINAL SANTA CRUZ			
		TÍTULO: CONTROLADOR DE VALVULA PCV - EPTA			
1	Pilot	Type Of Pilot		3 WAY ELEC./PNEUMATIC	
2		Pilot		Yes	
3		Supply To Pilot		GAS POWER	
4		Self Cont	Ext. Conn	Yes	No
5		Diaphragm Material		Silicona sobre poliéster	
6		Diaphragm Rating		250 psig	
7		Spring Range		140-250 (Blue)	
8		Minimun Set Point		140 Psig	
9		Pilot Model		Feeldback	
10	Accesories	Filter	Supply Gage	Yes	No
11		Handwheel	Housing Vent	No	No
12		Internal Relief		No	
13		Positioner		By operador HMI; 4-20mA	
14	Fabricante / Proveedor	Catalogo, con detalle de selección de modelo de valvula		Si	
15		Verificación de memoria de Calculo		Si	
16		Pruebas de funcionamiento taller-Proveedor		Si	
17		Certificaciones, SIL, ATEX		Si	
18		Manufacter / Model		BY VENDOR	
Notes: 1.- IMAGEN TIPICO (CONTROLADOR DE VALVULA PCV, MOSTRADA EN LA VALVULA PCV).					
<div style="display: flex; justify-content: space-around; align-items: center;">   </div>					