DESDE CAMPO

GABINETE ESD/SCP-01

INSTRUMENTOS DE CAMPO

BORNERA FRONTERA

RACK 03 CHASIS I/O ESD SLOT 02

PANTALLA HMI

TB-DI-ESD-02

TBP-24V / 11

ESTATUS SHUTDOWN, COMPRESORDE GAS UCG#01	XS 0102	XS-0102[+] / XS-0102[-]	1C-1Px16AWG	XS-0102[+] / XS-0102[-]	37 / 38	MODULO: 1756-IB32 SLOT: 2 CH: 18
ESTATUS RUN, COMPRESOR DE GAS UCG#02	XS 0200	XS-0200[+] / XS-0200[-]	1C-1Px16AWG	XS-0200[+] / XS-0200[-]	39 / 40	MODULO: 1756-IB32 SLOT: 2 CH: 19
ESTATUS FALLA, COMPRESOR DE GAS UCG#02	XS 0201	XS-0201[+] / XS-0201[-]	1C-1Px16AWG	XS-0201[+] / XS-0201[-]	41 / 42	MODULO: 1756-IB32 SLOT: 2 CH: 20
ESTATUS SHUTDOWN, COMPRESORDE GAS UCG#02	XS 0202	XS-0202[+] / XS-0202[-]	1C-1Px16AWG	XS-0202[+] / XS-0202[-]	43 / 44	MODULO: 1756-IB32 SLOT: 2 CH: 21
ESTATUS RUN, COMPRESOR DE GAS UCG#03	XS 0300	XS-0300[+] / XS-0300[-]	1C-1Px16AWG	XS-0300[+] / XS-0300[-]	45 / 46	MODULO: 1756-IB32 SLOT: 2 CH: 22
ESTATUS FALLA, COMPRESOR DE GAS UCG#03	XS 0301	XS-0301[+] / XS-0301[-]	1C-1Px16AWG	XS-0301[+] / XS-0301[-]	47 / 48	MODULO: 1756-IB32 SLOT: 2 CH: 23

PANTALLA HMI	TAG:	RANGO:	Hi-Hi Alm:	Hi Alm:	Lo Alm:	Lo-Lo Alm:
XS 0102	XS-0102	On / Off				
XS 0200	XS-0200	On / Off				
XS 0201	XS-0201	On / Off				
XS 0202	XS-0202	On / Off				
XS 0300	XS-0300	On / Off				
XS 0301	XS-0301	On / Off				

Bolinter

Av. Doble Vía a la Guardia, Km. 3½, entre 4to y 5to Anillo
+591-3-3529270
+591-3-3523713

http://www.bolinter.com
bolinter@bolinter.com

DOCUMENTOS DE REFERENCIA

SC-E30-IC-01-05-02 de 02 Layout General de Distribución del Sistema Fire & Gas

SIMBOLOGIA

- BORNE PORTAFUSIBLE
- BORNE DE PASO
- BORNE DE INSTRUMENTO DE CAMPO
- CABLE DE INSTRUMENTACIÓN
- CABLE 24 VDC GABINETE ESD/SCP
- CABLE CONEXIÓN INTERNA GABINETE ESD/SCP

YPFB TRANSPORTE S.A.

GERENTE DE PROY.: Ivan Meneses
REVISOR 1: Jafeth Achá
REVISOR 2: Walter Escobar
REVISOR 3: Álvaro Castro

BOLINTER LTDA

GERENTE DE PROY.: Franklin Argandoña
REVISOR 1: Wilbert Mendez
REVISOR 2: Jorge Medrano
REVISOR 3: Rudy Monasterio

FECHA	DIBUJO	REVISOR Calidad	REVISOR Técnico	APROBÓ	REV.N°	DESCRIPCIÓN	EMPRESA
09/Sep/24	SJ.Togo	R.Monasterio	J.Medrano	F.Argandoña	1	Conforme a Obra	Bolinter Ltda.
07/May/24	V. Lopez	R.Monasterio	W. Chavez	F.Argandoña	0	Aprobado para Construcción	Bolinter Ltda.

YPFB Transporte S.A.

Ubicación: Colpa - Belgica (SCZ)

Etapa: Conforme a Obra

Código: SC-E30-IC-01-03-29 de 93

Proyecto: Ingeniería y Construcción para el proyecto Estación de Compresión Colpa Fase I

Escala: S/E

Título del Plano: Diagrama de Lazo Sistema de Seguridad Señal Discreta [DI-02-4]

Formato: Tabloide: 279 mm x 432 mm

Formato Tabloide - YPFB TRANSPORTE S.A. Rev 3