



	PROYECTO: <b>INGENIERIA BASICA Y DE DETALLE MEJORAS OPERATIVAS DE TERMINAL SANTA CRUZ</b>	CÓDIGO DE DOCUMENTO: <b>SC-E01-IC-00-MCE-01</b>
	TITULO: <b>MATRIZ CAUSA - EFECTO</b>	HOJA: 2 de 4

Estación Terminal Santa Cruz					Tag																												
					Description																												
Description	Tag		Trip	N°	1	2	3	4	5	6	7	8	9	10	11	12					15	16	17						21	18	20		
Inlet pressure Transmitter from OSCS (crude from Caranda)	PIT-0001		HI/Hi	1																		X	X									X	
			HI																				X	X									X
			LO																				X	X									X
			LO/LO																				X	X									X
Inlet pressure Transmitter from ORSZ (Condensed from Rio Grande)	PIT-0002		HI/Hi	2																		X	X									X	
			HI																				X	X									X
			LO																				X	X									X
			LO/LO																				X	X									X
Inlet pressure Transmitter from OCSZ (CRUDE/LPG from Chorety)	PIT-0003		HI/Hi	3																		X	X									X	
			HI																				X	X									X
			LO																				X	X									X
			LO/LO																				X	X									X
Inlet pressure Transmitter from PRSZ (LPG from Rio Grande)	PIT-0004		HI/Hi	4																		X	X									X	
			HI																				X	X									X
			LO																				X	X									X
			LO/LO																				X	X									X
Inlet Pressure Transmitter from GLP Inlet (Line 109)	PIT-0226		HI/Hi	5																		X	X									X	
			HI																				X	X									X
			LO																				X	X									X
			LO/LO																				X	X									X
Inlet Pressure Transmitter from Crude B Inlet (Line 108)	PIT-0228		HI/Hi	6																		X	X									X	
			HI																				X	X									X
			LO																				X	X									X
			LO/LO																				X	X									X
outlet Presurre Transmitter to PRGS (Line 107)	PIT-0229		HI/Hi	7																		X	X									X	
			HI																				X	X									X
			LO																				X	X									X
			LO/LO																				X	X									X
outlet Presurre Transmitter to OCSZ (Line 124)	PIT-0231		HI/Hi	8																		X	X									X	
			HI																				X	X									X
			LO																				X	X									X
			LO/LO																				X	X									X
inlet Pressure Transmitter (Main pumps suction)	PIT-0021		HI/Hi	9								X	X		X	X	X	X				X	X									X	
			HI												X	X		X	X	X				X	X								X
			LO												X	X		X	X	X				X	X								X
			LO/LO												X	X		X	X	X				X	X								X
outlet Presurre Transmitter to OSSA (Main Station Outlet)	PIT-0020		HI/Hi	10								X	X		X	X	X	X				X	X									X	
			HI												X	X		X	X	X				X	X								X
			LO												X	X		X	X	X				X	X								X
			LO/LO												X	X		X	X	X				X	X								X
Inlet Temperature Transmitter from OSCS (crude from Caranda)	TIT-0001		HI/Hi	11																		X										X	
			HI																				X										X
			LO																				X										X
			LO/LO																				X										X



